

2014년도 신축공동주택 실내공기질 오염도 검사결과 (시공사)

자치구	공동주택명	시공사 상호	세대수	측정일자	측정 동호수	오염물질별 측정결과(μg/m³)					
						폼알데하이드 (210)	벤젠 (30)	톨루엔 (1000)	에틸벤젠 (360)	자일렌 (700)	스티렌 (300)
성동구	서울숲 더샵 행당주상복합	포스코건설	495	2014-07-23 2014-07-30	101-801	121.0	5.8	444.8	50.8	78.9	104.8
					101-2405	90.4	7.2	285.3	15.8	23.8	77.2
					102-2302	150.2	14.4	475.9	40.6	52.2	186.9
					103-3804	60.9	5.3	369.2	47.8	99.7	87.3
					103-803	76.3	5.6	222.0	71.6	70.6	109.7
					103-3704	57.8	5.8	180.8	14.7	34.0	48.3
성동구	왕십리뉴타운2구역 주택재개발	GS건설(주) 현대산업개발(주) 삼성물산 건설부문 대림산업(주)	1,148	2013-12-20	203-2302	22.2	0.5	96.9	25.3	36.4	2.4
					202-401	24.0	0.7	89.1	13.1	16.5	2.5
					201-1001	21.7	5.4	328.1	216.9	280.2	22.6
					212-1301	11.9	0.7	903.5	196.6	481.6	63.1
					214-931	16.6	4.6	505.4	185.8	606.3	19.0
					213-301	23.9	4.4	442.2	145.5	597.1	8.0
					209-802	15.6	3.7	128.8	51.8	168.2	9.6
					205-2002	42.6	4.4	333.2	227.1	288.7	18.8
					204-1301	24.7	4.3	289.8	279.7	355.5	17.9
					206-601	19.5	4.5	236.5	85.1	166.2	5.9
					207-502	15.8	4.3	111.4	19.5	71.0	5.4
					208-903	19.4	4.0	224.1	48.0	104.3	5.5
					210-1603	31.4	5.0	436.1	84.2	205.9	10.8
					211-401	29.0	3.5	153.0	39.1	105.8	4.3
동대문구	어진재	효진건설(주)	124	2014-03-19	212	28.3	3.8	217.0	120.5	376.8	3.2
					422	46.9	4.0	163.8	53.0	171.1	12.3
					517	33.2	3.8	182.9	77.3	240.6	9.2
동대문구	답십리매미안위브	두산건설(주)	873	2014-08-05	311-304	41.0	ND	516.8	152.4	147.7	45.6
					311-805	39.5	ND	252.8	110.8	ND	41.6
					311-1503	41.1	ND	388.1	68.9	ND	83.9
					310-205	34.6	ND	575.7	200.1	191.7	67.8
					310-703	37.2	ND	543.4	116.4	45.3	47.6
					310-1403	51.4	ND	195.5	57.5	ND	ND
					308-203	66.8	ND	133.4	N.D	ND	ND
					308-702	45.0	ND	201	98.2	ND	18.8
					308-1405	44.2	ND	312.2	33.5	ND	45
					306-205	76.7	ND	350.1	45	ND	60.9
					306-603	70.5	ND	292.1	38	ND	42.8
					306-1202	22.3	ND	267.8	50.2	ND	60.2
동대문구	답십리 래미안위브	삼성건설(주)	1779	2014-08-19 2014-08-20	103-305	20.8	4.0	276.7	60.5	93.9	8.8
					103-604	30.2	10.0	932.9	237.2	314.6	8.3
					103-702	19.3	4.4	296.3	73.4	105.2	5.3
					105-304	16.2	5.6	121.9	76.4	84.5	2.4
					105-305	16.1	3.4	167.6	35.8	63.5	4.1
					108-305	30.2	5.6	389.8	75.5	146.7	6.9
					201-801	22.3	4.2	171.5	79.1	89.6	3.3
					201-802	21.1	5.9	142.1	84.4	94.7	2.8
					204-1402	27.2	3.9	183.8	24.6	43.0	4.6
					204-1403	28.6	5.4	274.0	60.2	62.4	5.8
					205-1503	16.0	5.5	133.5	96.6	84.4	1.6
					205-1504	22.1	6.3	261.9	109.1	112.6	5.2
					402-202	19.9	7.1	295.9	88.4	111.5	6.0
					404-1203	35.8	5.3	717.9	44.4	99.9	6.9
					404-1204	33.3	11.4	956.2	64.9	147.0	7.1
					405-301	45.5	5.6	399.7	50.5	105.9	29.8
					407-1401	21.2	3.5	260.7	20.6	44.8	4.6
					407-1402	20.9	3.3	237.9	20.1	43.1	3.7
					408-1002	23.5	3.8	233.2	24.2	51.5	3.7
중랑구	포시티	한건 종합건설	120	2014-04-30	502	18.5	8.0	407.0	49.9	101.9	3.4
					1105	24.0	1.0	666.0	120.3	166.7	2.7
					1607	26.2	9.5	447.5	55.7	115.4	3.9

자치구	공동주택명	시공사 상호	세대수	측정일자	측정 동호수	오염물질별 측정결과(μg/m³)					
						폼알데하이드 (210)	벤젠 (30)	톨루엔 (1000)	에틸벤젠 (360)	자일렌 (700)	스티렌 (300)
중랑구	우디안Ⅱ단지아파트	한신공영 주식회사	1,402	2014-05-16	101-801	50.2	2.5	468.5	23.7	28.2	36.2
					102-103	11.0	1.7	100.9	8.3	17.5	11.8
					103-1201	58.9	2.6	509.8	23.6	29.8	55.9
					104-1304	45.8	2.2	402	21.4	32.8	29.9
					105-303	61.7	2.3	399.1	36.5	67.2	19.9
					106-1401	76.8	2.4	423.9	37.6	59.6	57.9
					107-1202	86.5	2.7	422.4	32.7	33.9	50.3
					108-302	67.6	2.2	298.9	22.1	30.6	26.9
					109-2108	57.3	2	322	29.6	46.8	46.9
					110-1202	70.5	2.6	449.9	38.7	30.5	121.6
					111-307	61.5	1.7	312.2	31.6	43.9	33.4
					112-2203	53.9	2.2	470.7	20.5	32.9	61.9
					113-1301	30.2	2.3	354	18.7	28.8	50
					114-302	44	2.3	423.4	18.8	24.9	36.2
					115-2002	69.5	2.5	491.2	23.8	28.9	71.7
					116-1402	51.4	3.1	489.1	27.1	26.8	70.2
성북구	금호어울림 센터힐아파트	금호건설(주)	490	2014-10-17 2014-10-22	101-2102	80.7	1.6	333.4	85.4	165.3	8.5
					102-201	90.0	4.0	439.6	127.5	266.1	15.1
					103-1002	87.4	5.0	508.1	156.2	331.0	19.7
					104-2204	50.6	6.1	444.1	137.6	296.8	17.8
					105-901	54.2	6.2	457.4	143.2	309.1	18.7
					106-303	60.6	6.2	459.5	148.5	321.6	19.4
강북구	수유역푸르지오시티	(주)대우건설	298	2014-10-20	323호	33.7	2.5	304.2	70.8	15.6	15.6
					418호	40.1	2.8	167.6	54.4	22.8	22.8
					1016호	50.5	2.3	229.6	95.5	23.5	23.5
					1121호	61.9	5.1	301.3	129.0	25.0	25.0
					1223호	59.4	3.8	289.0	110.0	24.3	24.3
노원구	소담빌 오피스텔	광성산업개발(주)	149	2014-03-05	309	42.9	3.3	409.9	86.7	143.4	4.3
					618	72.6	4.2	654.3	80.3	104.8	228.7
					914	49.2	2.8	532.8	43.9	77.0	123.0
노원구	중계한화꿈에그린 The First	한화건설(주)	283	2014-07-29	101-1102	142.8	17.5	612.8	209.2	525.2	131.8
					102-301	141.1	13.5	509.7	192.3	493.1	124.7
					103-303	128.2	13.7	522.8	194.6	498.5	125.2
					103-2602	141.1	15.1	584.6	217.4	559.7	140.9
					104-703	143.8	19.9	723.9	262.5	658.8	162.9
서대문구	홍제동대학생연합기숙사	디엔씨건설(주)	208	2014-08-05	2F-208	6.4	3.2	46.2	1.6	불검출	3.1
					4F-431	6.7	3.1	52.1	3.6	2.3	3.5
					5F-505	5.5	3.4	203.1	8.7	33.1	18.0
					7F-715	14.4	3.6	200.2	10.2	94.0	28.8
마포구	마포자이2차아파트	GS건설	558	2014-02-13	102-1103	21.6	4.6	613.7	125.9	136.7	188.0
					103-1301	28.6	3.7	369.4	38.4	47.2	93.2
					103-2002	38.6	3.5	349.4	44.7	65.7	161.3
					104-1102	83.2	4.2	870.6	186.5	193.3	200.1
					104-2502	38.7	4.6	549.2	221.4	212.0	241.9
					105-301	32.5	5.6	376.9	151.2	198.3	211.8
					105-1101	29.1	4.5	899.9	104.8	167.1	239.1
					106-301	101.7	5.3	714.1	123.8	15.1	239.1
					106-502	44.5	6.0	237.0	55.4	86.5	49.6
마포구	래미안마포리버웰아파트	삼성물산	563	2014-06-24	101-1103	39.9	1.9	513.0	63.3	124.4	7.4
					101-2204	37.2	2.4	522.7	89.1	175.9	10.4
					102-204	45.2	2.9	498.3	119.2	231.9	45.5
					103-902	30.1	2.3	459.0	62.7	124.7	13.3
					106-1703	53.9	2.9	730.4	147.6	290.1	19.3
					107-302	45.2	4.6	478.9	61.5	120.1	7.7
					109-807	49.8	2.1	738.5	165.6	323.5	20.8

자치구	공동주택명	시공사 상호	세대수	측정일자	측정 동호수	오염물질별 측정결과(μg/m³)					
						폼알데하이드 (210)	벤젠 (30)	톨루엔 (1000)	에틸벤젠 (360)	자일렌 (700)	스티렌 (300)
마포구	마포래미안푸르지오아파트	삼성물산	1884	2014-08-26	301-1704	43.5	1.1	369.9	43.5	93.8	12.2
					302-1105	56.1	ND	335.1	56.1	119.3	13.1
					303-302	62.2	2.0	437.1	62.2	86.9	14.0
				2014-09-11	304-2201	23.6	6.7	878.1	23.6	42.2	12.3
				2014-08-26	307-1204	37.2	1.6	287.0	37.2	51.5	11.9
				2014-09-11	310-301	13.0	5.6	185.0	13.0	20.5	5.3
				2014-08-26	401-1001	41.1	1.1	527.2	41.1	71.1	18.6
				2014-09-11	402-205	16.7	6.1	118.8	16.7	26.7	6.6
				2014-08-26	403-2904	108.3	1.6	444.1	108.3	173.8	19.2
					404-1503	57.5	1.9	527.8	57.5	120.4	19.3
				2014-08-27	405-305	30.8	ND	111.5	28.1	85.7	9.7
					406-1603	34.6	1.1	49.0	101.0	175.2	19.7
				2014-09-11	407-702	25.2	4.6	892.7	138.9	248.6	5.6
				2014-08-27	408-303	49.2	ND	338.0	44.4	77.1	12.3
					408-403	39.9	ND	468.4	121.1	250.2	15.0
					409-1101	42.5	1.3	320.2	94.3	234.3	14.6
				2014-09-11	410-1404	43.2	8.5	319.1	41.6	44.7	8.7
				2014-08-27	412-2204	32.1	ND	317.7	48.7	131.5	9.6
					413-1304	28.2	1.1	256.1	27.1	45.0	15.5
					414-301	26.0	ND	383.6	41.7	69.0	9.2
마포구	마포래미안푸르지오아파트	대우건설	2001	2014-08-18	101-701	71.1	4.7	153.4	5.8	8.9	3.6
					102-301	34.4	3.8	135.3	30.1	35.3	6.6
					103-2201	43.3	4.6	341.8	205.7	189.4	8.0
					104-1101	54.9	3.9	205.3	20.3	26.7	10.3
					105-301	37.3	3.7	137.8	12.5	15.0	7.1
					106-2002	57.7	3.8	430.6	72.8	123.8	18.0
					107-1102	58.5	5.4	212.8	103.2	160.6	11.2
					108-302	49.3	3.7	74.6	11.4	18.2	3.8
					305-2002	41.3	3.9	145.7	26.4	44.4	9.9
				2014-08-25	306-1006	69.8	5.9	390.0	154.5	263.3	8.6
				2014-08-19	201-2201	61.9	6.3	715.8	51.9	116.7	43.7
					202-1001	179.6	3.6	677.8	54.2	67.5	24.5
					203-302	107.3	11.0	159.9	26.9	37.4	9.2
				2014-08-25	204-1501	160.3	5.0	391.1	95.8	118.5	26.9
					205-801	79.6	5.8	591.0	111.3	307.6	26.6
					206-301	33.9	5.2	557.1	113.9	219.0	23.8
					207-1202	41.3	5.1	924.2	87.5	245.6	17.7
				2014-08-25	208-1301	179.5	5.8	460.2	79.6	142.9	25.1
					209-301	135.1	5.2	482.3	59.8	106.4	15.1
					210-2501	90.7	2.8	213.1	32.4	65.7	8.1
				2014-08-19	211-701	58.9	3.9	714.2	80.2	150.6	9.1
				2014-08-25	212-301	121.7	5.1	425.6	119.9	174.1	17.4
마포구	래미안밤섬리베뉴 I 아파트	삼성물산	429	2014-10-01	101-2404	32.3	12.0	263.8	31.3	142.3	4.9
					102-1104	18.3	6.1	98.9	11.5	40.6	2.5
				2014-10-02	103-1104	20.0	12.1	301.8	39.3	83.8	6.9
				2014-10-01	103-1902	30.6	6.7	144.5	15.2	62.8	3.5
					104-302	27.0	9.1	182.9	17.7	68.7	2.9
				2014-10-14	106-205	9.1	20.6	125.4	11.6	68.8	2.4
마포구	래미안밤섬리베뉴Ⅱ아파트	삼성물산	530	2014-10-02	203-303	33.6	7.7	79.6	43.4	156.0	13.6
					203-902	28.1	28.7	126.6	42.9	191.6	13.0
					203-1701	23.4	10.9	60.5	19.3	59.9	9.7
					206-301	26.0	5.2	94.0	15.3	61.1	3.0
					206-1201	23.1	4.8	80.2	10.9	41.8	2.2
					206-2202	17.3	3.5	68.4	10.4	42.9	1.9
					208-501	25.7	11.0	139.9	55.6	212.5	5.9
				2014-10-14	201-203	14.4	2.7	58.8	15.2	53.0	2.0
					202-802	14.9	2.3	103.1	9.6	33.6	2.0
					204-1004	7.0	2.2	48.7	5.5	12.0	2.2
					205-303	8.9	2.9	65.3	7.1	21.6	2.8
					207-904	16.2	8.7	112.1	36.0	133.7	3.7

자치구	공동주택명	시공사 상호	세대수	측정일자	측정 동호수	오염물질별 측정결과(μg/m³)					
						폼알데하이드 (210)	벤젠 (30)	톨루엔 (1000)	에틸벤젠 (360)	자일렌 (700)	스티렌 (300)
양천구	롯데캐슬아파트	롯데건설(주)	930	2014-01-12	107-304	81.4	11.3	130.2	56.1	32.1	불검출
					107-1004	57.6	9.6	118.5	52.4	25.5	불검출
					107-1904	98.0	8.5	80.8	38.2	14.2	불검출
					108-507	101.5	4.4	64.2	30.5	37.3	8.3
					108-1007	69.6	8.4	114.9	50.0	50.0	12.4
					108-1807	50.9	2.9	54.1	26.7	32.2	5.9
					103-302	49.5	6.4	80.8	39.3	42.7	8.0
					105-304	82.5	2.9	55.8	28.7	35.2	4.7
					105-1804	67.9	4.2	58.6	31.1	36.0	5.4
					102-1002	81.2	2.5	50.1	26.1	32.7	4.1
					110-1107	38.3	4.3	61.1	30.5	35.0	4.7
강서구	강서힐스테이트	현대건설(주)	2603	2014-05-19	105-903	18.4	0.7	940.4	12.4	41.5	30.3
					108-1002	33.8	2.4	213.1	35.4	79.3	26.0
					109-2002	13.4	2.1	696.9	37.5	267.4	127.7
					110-801	33.6	3.0	672.3	86.3	331.1	83.7
					114-104	17.1	4.3	685.4	93.2	376.7	68.3
					115-301	24.8	불검출	713.2	62.7	152.4	68.9
					117-1401	13.7	2.4	855.4	69.7	172.9	57.0
					118-2002	24.5	6.5	314.7	51.2	155.4	108.7
					102-301	55.0	0.9	646.9	65.8	132.6	77.5
					103-1703	39.4	2.3	944.7	58.4	114.2	107.3
					104-204	47.4	2.0	935.5	91.2	141.7	20.7
					107-1004	64.8	1.8	748.1	74.4	133.6	14.7
					111-802	41.5	2.6	957.1	105.4	181.8	139.6
					112-701	24.5	2.2	782.7	48.1	154.1	46.3
					113-1903	51.6	2.5	921.6	91.7	335.2	146.3
					116-1501	32.9	1.2	558.6	193.2	400.8	25.3
					122-1002	17.6	1.9	469.3	35.2	98.4	49.3
					101-303	17.0	1.9	657.2	195.2	498.2	157.4
					106-1101	26.4	불검출	804.4	69.8	241.3	28.0
					119-101	12.8	2.8	789.7	63.2	153.6	141.5
					120-805	12.4	3.1	373.9	55.5	241.8	175.9
					121-102	24.5	불검출	892.8	67.9	334.7	226.3
					123-204	22.8	3.6	925.4	79.6	168.1	79.7
					124-1802	12.7	1.6	346.4	89.2	447.3	85.9
					125-1001	15.5	불검출	541.7	71.1	285.6	126.8
					128-1903	36.5	불검출	465.1	54.2	216.8	131.4
					129-1003	34.6	불검출	354.6	35.6	135.7	138.3
					133-201	15.7	불검출	720.9	71.4	270.3	77.7
강서구	마곡엠밸리1단지	한양(주)	237	2014-05-16	101-209	8.8	3.0	178.3	53.7	395.1	18.2
					102-603	34.1	2.7	144.7	35.1	235.1	7.3
					103-903	72.4	2.7	189.9	24.9	81.0	16.9
					104-704	14.9	3.5	233.9	40.0	174.8	17.9
강서구	마곡엠밸리2단지	한양(주)	408	2014-05-16	201-1301	63.8	4.3	133.7	16.7	50.1	89.4
					202-402	20.4	1.8	60.5	41.1	253.3	3.5
					203-1108	38.0	2.3	158.3	13.0	46.9	13.9
					204-403	33.6	2.5	192.8	81.0	531.2	28.9
					205-705	35.7	2.0	174.2	22.9	103.0	7.1
					206-808	34.0	2.0	190.9	40.6	221.6	8.8
강서구	마곡엠밸리3단지	한양(주)	315	2014-05-16	301-816	18.3	4.6	240.5	32.3	97.4	34.3
					303-204	37.5	5.1	226.8	83.4	333.6	54.4
					304-1101	40.9	2.0	170.5	15.9	40.3	9.6
					302-805	23.0	3.5	217.6	43.2	236.6	6.5
					302-502	35.4	4.1	118.3	35.8	159.1	103.3

자치구	공동주택명	시공사 상호	세대수	측정일자	측정 동호수	오염물질별 측정결과(μg/m³)					
						폼알데하이드 (210)	벤젠 (30)	톨루엔 (1000)	에틸벤젠 (360)	자일렌 (700)	스티렌 (300)
강서구	마곡엠밸리4단지	경남기업㈜	420	2014-05-28	401-801	77.5	0.0	604.8	21.1	61.1	71.6
					402-205	77.8	0.0	502.1	18.6	33.4	22.8
					403-1401	104.1	0.0	405.1	16.3	47.3	137.4
					404-503	67.5	0.0	485.9	14.2	42.4	49.0
					406-204	52.0	0.0	530.3	30.3	102.0	119.9
					407-1401	47.5	0.0	719.5	75.5	304.8	62.8
강서구	마곡엠밸리5단지	티이씨건설㈜	439	2014-05-26	501-302	49.0	0.0	991.3	227.5	130.2	223.0
					502-718	64.0	0.0	891.7	87.7	80.7	287.9
					503-602	39.3	0.0	761.3	19.0	40.7	141.2
					503-701	38.8	0.0	743.4	17.8	37.7	157.6
					504-301	62.3	0.0	995.0	247.4	274.1	262.1
					506-904	105.3	3.5	739.2	18.6	38.8	156.6
					507-1104	70.1	3.7	796.9	20.4	186.9	173.8
강서구	마곡엠밸리6단지	경남기업㈜	1466	2014-05-20	601-304	43.2	0.0	890.5	27.5	32.3	34.8
					601-701	30.9	0.0	884.8	63.5	100.1	246.7
					601-712	45.7	0.0	850.2	84.4	90.5	165.4
					602-707	35.9	2.9	671.3	72.6	115.7	141.8
					602-723	59.9	0.0	880.2	64.3	67.6	167.6
					604-403	38.7	0.0	904.4	72.9	77.7	201.1
					605-402	39.8	0.0	961.1	75.3	102.2	224.3
					608-703	37.5	0.0	890.2	57.4	134.0	124.3
					609-304	37.3	3.2	464.1	34.1	54.1	90.6
					609-1502	49.4	0.0	969.0	72.4	99.7	196.5
					612-304	37.0	0.0	623.7	48.7	83.4	89.3
					612-1403	57.1	0.0	934.7	80.8	180.3	182.9
					613-304	34.8	0.0	742.2	43.9	70.9	151.3
					613-1403	66.8	8.4	845.5	78.5	138.0	134.1
					618-302	49.9	0.0	797.9	34.2	67.8	34.0
					618-1002	50.2	0.0	727.2	32.2	102.8	32.3
강서구	마곡엠밸리7단지	금호건설	1004	2014-05-29	701-303	148.3	0.0	674.7	73.6	142.3	272.3
					703-1504	92.7	0.0	831.3	62.2	179.7	179.8
					705-712	149.6	0.0	390.8	39.9	57.8	170.2
					706-310	90.5	0.0	753.2	33.2	54.9	208.3
					708-1402	98.0	0.0	326.9	32.5	50.6	140.5
					709-105	131.1	0.0	389.8	38.3	97.2	173.7
					709-801	58.6	7.5	766.8	73.0	136.9	225.5
					710-404	51.0	5.4	682.1	87.0	173.2	215.2
					711-905	161.7	6.9	824.8	86.2	160.1	268.2
					712-1401	123.2	5.9	610.1	72.9	140.4	243.3
					712-1403	49.4	6.4	632.3	53.4	112.1	135.7
					714-701	88.3	0.0	773.0	37.4	83.7	175.1
강서구	마곡엠밸리14단지	㈜한화건설	1270	2014-04-24	1401-204	23.6	3.1	440.5	69.2	329.8	108.4
					1402-1303	14.6	1.3	166.4	96.6	571.1	10.0
					1403-304	15.9	0.8	333.3	20.0	46.2	15.9
					1404-703	19.6	ND	641.2	49.3	168.1	26.6
					1405-201	14.2	0.8	337.7	20.2	77.5	15.8
					1406-1405	21.7	3.0	723.8	14.9	57.1	25.9
					1407-202	24.3	1.0	256.1	15.9	31.5	12.0
					1407-906	29.5	2.8	311.9	13.0	30.7	18.4
					1408-302	31.0	1.5	341.1	36.3	192.5	3.9
					1409-1502	30.9	ND	475.1	20.3	60.5	8.7
					1410-704	23.2	ND	424.3	14.5	121.8	7.4
					1411-202	16.7	ND	744.4	6.7	12.0	1.8
					1413-801	36.4	ND	331.3	5.4	11.2	1.8
					1413-1501	6.2	ND	174.1	6.6	15.3	1.6
					1412-1504	45.3	ND	1536.7	8.7	16.6	0.7
					경로당	16.3	ND	105.6	6.6	18.7	ND
					보육시설	21.3	ND	473.6	30.8	115.2	27.5

자치구	공동주택명	시공사 상호	세대수	측정일자	측정 동호수	오염물질별 측정결과(μg/m³)					
						폼알데하이드 (210)	벤젠 (30)	톨루엔 (1000)	에틸벤젠 (360)	자일렌 (700)	스티렌 (300)
강서구	마곡엠밸리15단지	대우조선해양건설(주)	1171	2014-04-07	1501-1401	45.0	1.5	661.3	23.5	ND	18.4
					1502-1402	24.7	3.5	201.9	7.9	12.2	5.9
					1503-203	17.2	2.0	454.9	22.4	319.1	32.3
					1504-304	42.5	3.5	642.8	219.2	106.6	178.8
					1513-305	18.4	1.8	184.1	6.4	29.9	9.1
					1505-903	13.9	3.8	521.3	14.6	210.5	21.6
					1506-603	22.9	3.8	838.6	37.1	77.3	58.1
					1507-504	23.8	4.3	285.9	6.4	48.7	8.6
					1508-904	38.3	3.1	337.7	6.1	32.6	8.2
					1509-601	20.0	2.6	253.3	7.8	15.6	8.9
					1510-1402	2.4	1.3	107.7	2.3	16.7	1.9
					1511-1403	23.4	1.3	118.2	0.2	13.8	1.8
					1512-205	27.8	1.1	521.3	20.1	7.3	39.3
강서구	강서쌍용예가	쌍용건설(주)	152	2014-05-02	101-1102	40.4	0.0	641.7	112.1	165.2	4.3
					102-201	52.7	0.0	546.0	125.1	176.9	4.0
					103-1803	92.5	0.0	513.3	127.9	177.1	0.0
					104-1002	71.7	0.0	664.7	249.3	361.0	13.4
강서구	내발산동(주)공기숙사	국제건설(주), (주)푸르미건설	152	2014-03-24	A520호	17.1	1.3	1189.8	37.5	37.4	91.2
					A634호	9.4	0.3	767.5	22.2	23.1	21.0
					B207호	8.7	1.4	857.6	13.5	26.5	15.8
구로구	로제리움2차	신세계건설	141	2013-12-26	1407	30.5	4.2	640.2	37.7	75.6	41.5
					1707	49.6	4.5	637.1	38.6	77.7	53
					2007	31.8	4.6	587.1	36.4	74	41.2
구로구	천왕2지구2단지	금호산업	1018	2014-01-09	201-504	49.7	8.8	498	112	284.1	99.7
					202-1201	43.8	16.4	859.7	82	164.7	83.9
					203-604	74.1	20.9	728.4	135.6	407.5	62.3
					205-501	50.7	9.9	419.6	54.2	159.3	17.7
					205-1003	52.4	13.3	689.9	153.4	310.9	39.2
					207-701	67	17.7	763.2	191.3	478.2	7.4
					208-1406	55.6	11.6	595.7	139.4	370.3	14.4
					209-503	77.6	11.6	603.2	145.2	375	14.9
					210-1002	64.3	13.7	531.6	109.7	244.9	98.5
					212-1704	36.1	15.7	833	82.7	255.9	11.0
					214-1204	55.3	15.6	850.4	81.1	247.3	11.1
					215-1203	47.1	15	666.2	196.3	332.5	193.9
구로구	현대비에스앤씨(주)	현대비 에스앤씨(주)	200	2014-04-25	710	28.25	2.16	354.87	249.3	272.78	53.16
					1122	27.67	2.56	342.55	190.25	211.45	97.52
					1201	35.57	3.04	396.55	304.21	467.43	161.32
					1615	31.43	2.94	431.12	334.16	427.28	167.76
구로구	개봉(주)푸르지오(아)	대우건설	978	2014-04-25	101-301	43.2	2.2	781.8	56.7	113.5	62.7
					101-2501	24.6	2	477.3	141.1	125.9	20.4
					102-1402	20.1	1.9	307.9	21	26.2	2.1
					103-2504	19.5	4.4	506.9	26.6	56.1	9.9
					104-1404	30.6	5.9	453.1	46.1	99.3	2.7
					105-1302	36.7	4.5	747	85.4	207.6	13
					106-303	27.7	4.8	711.9	261.7	227.5	19.7
					107-305	7.7	1.6	765	39.9	45.1	2.1
					108-2502	38.6	3.2	534.6	208	391.9	12
					109-303	43.3	1.8	361.7	23.7	29.5	1.8
					110-1402	22.2	3.1	894.6	35.4	45.3	8.6
구로구	포스시티	소사벌종합건설(주)	102	2014-07-16	1205	93.2	7.4	658.9	70.7	95.7	298.5
					1502	134.1	5.5	771.9	66.8	80.2	237.2
					1801	85.5	0	786.1	51	71.8	169.2

자치구	공동주택명	시공사 상호	세대수	측정일자	측정 동호수	오염물질별 측정결과(μg/m³)					
						폼알데하이드 (210)	벤젠 (30)	톨루엔 (1000)	에틸벤젠 (360)	자일렌 (700)	스티렌 (300)
영등포구	영등포아트자이	GS건설㈜	836	2014-01-22	101-1501	18.9	1	250.3	72.1	74.7	6.1
					101-3002	19.6	1.2	785.2	259.1	253.5	3.9
					102-301	10.1	0.8	247.9	16.7	14.6	4.9
					104-1501	21	1	289.9	66.7	65.7	9.5
					104-2702	9.5	1	236.3	146.6	144.8	6.4
					105-302	16.6	1.2	318.8	76.9	70.3	16
					105-1501	10.5	1.5	198.6	37.7	50.7	3.9
					106-304	35.2	0.7	115.3	12.3	11.3	1.6
					106-2903	21.7	1	368.5	80.6	89.8	38.1
					108-205	6.2	0.8	19.7	6.1	7.2	1.3
					108-1102	9.4	0.7	41	29.7	27.2	1.3
영등포구	영등포 당산계룡리슈빌	계룡건설산업㈜	292	2014-09-04	101-802	95.5	5.9	684.3	140.7	139.7	12.8
					101-903	60.3	3.4	312.7	39.1	36.7	16
					102-1902	56.1	5	884.3	81.6	122.1	38.1
					102-202	61.7	3.5	306.5	224.4	270.9	0.6
영등포구	당산계룡리슈빌(3단지)	계룡건설산업㈜	149	2014-11-28	102-2001	31.7	16.5	781.3	422.3	221.6	49.9
					102-1201	31.1	2.9	615.5	193.3	103.6	12.3
					102-201	43.3	5.5	514.1	96	57.2	16.8
동작구	포스코더샵-#아파트	(주)포스코건설	138	2014-03-06	202-201	14.6	2.8	743.1	93.5	387.0	8.7
					202-1201	11.4	2.3	810.5	132.5	555.7	39.4
					204-601	41.7	3.3	705.8	37.5	132.7	50.5
동작구	스마티움	코렘시스㈜	114	2014-08-25	208	14.4	1.3	409.5	39.1	38.8	13.8
					507	12.1	1.3	991.9	340.7	2.3	41.1
					807	17.7	1.3	819.4	147.4	33.1	24.0
관악구	봉천동 서희스타힐즈	(주)서희건설	142	2014-08-26	404	28.4	3.4	662.2	72.7	138.2	44.2
					901	21.0	2.5	688.9	24.4	138.2	26.5
					1305	42.6	2.9	746.2	62.1	117.5	29.9
관악구	대우 푸르지오	㈜대우건설	363	2014-08-26	102-504	12.9	2.3	28.1	2.0	5.1	0.4
					102-2004	17.8	1.9	32.8	2.6	6.5	0.4
					103-201	27.7	2.9	73.2	20.1	78.8	1.7
					103-2201	16.3	1.3	38.1	4.6	15.3	1.1
					104-504	16.3	1.3	38.1	4.6	15.3	1.1
					104-2104	20.2	1.4	34.2	5.1	16.8	0.5
서초구	SH 내곡지구 5단지	한신공영㈜	547	2014-04-21	501-1504	38.0	2.5	419.5	48.0	63.8	198.1
					502-206	40.6	3.3	538.3	62.9	109.1	103.1
					502-804	52.2	3.7	835.2	46.2	65.9	234.9
					503-304	43.5	3.4	499.2	25.6	100	144.2
					503-501	42.7	2.4	417	21.5	78.4	109.5
					504-201	41.1	2	459.2	40.1	78.4	150.7
					509-1003	49	2.5	950.2	136.8	192.4	283.1
					511-802	33.5	2.7	362.2	34.6	54.3	178.3
서초구	양재리본타워2단지	금호산업(주)	390	2014-04-17 2014-04-28	201-302	80.3	20.3	836.2	38.5	338.2	158.2
					201-1301	67.5	16.2	863.7	46.9	388.7	177.7
					202-203	68.3	16.4	783.4	40.1	335.7	150.2
					202-2404	80.2	15.9	739.6	35.1	271.4	117.8
					203-1706	79.3	20.1	825.2	38.0	333.7	156.1
					203-3303	65.7	15.7	840.6	45.6	378.3	172.9

자치구	공동주택명	시공사 상호	세대수	측정일자	측정 동호수	오염물질별 측정결과(μg/m³)					
						폼알데하이드 (210)	벤젠 (30)	톨루엔 (1000)	에틸벤젠 (360)	자일렌 (700)	스티렌 (300)
서초구	SH 내곡지구 3단지	한신공영(주)	482	2014-05-28	301-301	52.0	1.9	207.1	12.2	55.0	42.1
					301-302	63.2	2.0	318.2	13.7	47.2	84.4
					302-601	70.4	2.3	326.1	17.7	82.6	81.6
					302-602	54.4	2.1	415.8	24.1	128.6	81.3
					306-1701	50.3	1.9	177.2	12.2	35	75.6
					306-1702	56.1	2.5	149	22.1	33.1	58.1
서초구	SH 내곡지구 1단지	포스코건설	1264	2014-07-04 2014-07-10	102-202	46.5	6.5	382.4	32.8	122.0	36.0
					103-1803	71.1	6.8	657.5	55.4	223.6	82.4
					105-202	86.8	4.2	670.0	56.4	129.7	77.2
					106-1701	68.4	4.4	439	29.4	88.6	60.9
					107-904	88.1	5.1	497.3	21	34.3	55.8
					108-302	136.3	5.1	787	64.8	166.4	131.2
					109-903	79.1	5.1	603.8	35.5	121.7	74.7
					111-1501	30.3	5.1	478.1	31.6	107.1	61.9
					112-902	40.4	4.6	189.6	16.1	50.3	25.2
					113-303	88.2	4.2	515.6	22.9	49.2	75.7
					114-1404	85.5	4.7	625.5	25.2	50.6	82.1
					115-601	57.6	4.6	654.6	51.1	154.7	58
					116-302	92.4	4.5	536.1	27.2	88.6	35.3
					118-401	103.2	5.1	839.7	52.9	157.9	86.5
서초구	서초캐슬프레지던트	롯데건설(주)	273	2014-10-06	101-303	148.9	0.0	335.4	65.2	69.0	16.1
					102-2501	163.7	0.0	645.8	82.3	212.8	39.0
					103-1605	191.0	0.0	969.8	147.1	302.9	19.8
					103-1702	161.3	0.0	760.7	192.5	354.5	35.8
서초구	내곡지구 4단지	현대엔지니어링(주)	256	2014-12-01	101-902	8.3	1	86.5	13.7	67.5	7.5
					102-503	8.9	1.7	176.3	31.9	180	10.1
					104-801	23.5	3	689.1	120.3	495.5	94.4
					109-202	9.6	2.1	77.3	33.4	180.7	5.8
강남구	성보아파트	현대산업개발	411	2014-02-21	101-602	45.2	0.0	407.7	22.8	15.9	0.0
					102-301	25.1	0.0	147.4	17.9	20.9	0.0
					102-1302	28.9	0.0	312.3	50.6	31.5	0.0
					103-303	37.9	0.0	243.8	42.0	39.0	0.0
					103-2003	34.0	0.0	569.2	177.4	311.4	23.2
					104-1302	40.0	0.0	124.3	9.6	19.9	0.0
					104-2004	48.7	0.0	234.6	13.6	50.2	0.0
					105-1301	51.6	0.0	318.8	148.3	310.8	194.2
					106-302	23.3	0.0	280.1	42.2	175.6	0.0
강남구	강남보금자리A6-BL	삼성물산	1020	2014-06-15	602-201	94.2	2.4	791.5	46.3	99.2	9.3
					602-301	60.9	2.2	641.1	46.0	131.1	11.8
					606-701	69.3	3.4	680.2	23.1	72.1	29.0
					606-702	72.9	1.8	762.8	55.0	94.1	28.9
					606-1202	66.2	3.6	761.8	160.4	344.7	25.7
					607-303	32.3	1.9	489.1	14.8	42.0	7.9
					607-704	56.7	1.9	667.3	19.4	47.2	21.6
					610-702	44.1	1.9	341.5	20.1	82.0	13.2
					616-201	109.3	2.9	643.6	111.7	312.7	23.7
					616-702	83.6	3.7	764.8	125.8	410.4	30.6
					616-1202	40.3	3.0	258.0	12.6	42.8	6.9
					617-701	50.8	2.7	550.5	30.2	107.8	12.8
강남구	세곡2지구 4단지	(주)한양울트라건설	1304	2014-02-20	405-901	112.7	11.7	568.9	90.6	149.3	254.3
					406-202	122.3	17.2	416.1	73.9	87.5	156.1
					407-906	125.0	15.4	437.3	82.2	139.1	201.6
					408-605	105.7	6.6	556.5	22.2	174.7	30.0
					409-203	39.3	10.0	730.5	153.5	507.1	45.6
					410-903	125.8	10.9	472.6	83.5	271.6	210.3
					411-501	110.0	0.8	501.1	31.9	164.0	166.1
					412-201	47.6	1.5	630.7	52.2	269.8	273.9
					415-201	127.7	0.7	444.8	29.4	151.8	154.6
					419-604	43.2	1.2	592.8	46.1	243.5	250.6
					420-904	149.7	2.7	792.2	142.0	494.4	211.7
					421-502	112.6	1.7	607.9	64.0	103.7	293.6
					422-206	36.6	1.9	651.5	118.9	370.3	78.9
					423-804	129.0	10.6	536.9	217.7	523.9	10.9
					424-501	128.9	1.2	615.6	45.4	234.1	238.2

자치구	공동주택명	시공사 상호	세대수	측정일자	측정 동호수	오염물질별 측정결과(μg/m³)					
						폼알데하이드 (210)	벤젠 (30)	톨루엔 (1000)	에틸벤젠 (360)	자일렌 (700)	스티렌 (300)
강남구	세곡2지구3단지	삼성물산㈜	1070	2014-03-12	301-302	8.6	2.8	273.0	56.2	70.2	6.0
					301-630	13.4	3.5	943.0	91.3	175.9	33.9
					302-603	16.1	2.8	335.1	37.2	41.1	8.6
					303-901	10.7	3.3	547.2	81.7	115.7	37.5
					303-902	1.4	2.5	251.8	46.4	76.5	8.0
					306-604	13.2	3.2	559.4	50.0	87.1	41.4
					307-1105	18.5	2.3	533.5	43.1	157.1	38.8
					310-306	7.0	ND	182.6	15.2	68.0	2.2
					311-507	10.4	6.1	277.2	20.7	33.1	10.6
					312-802	9.1	1.2	201.0	30.5	42.5	3.7
					313-201	10.9	1.9	159.7	15.2	44.7	2.2
					313-202	9.8	2.2	125.6	11.2	19.3	2.1
강남구	세곡2지구 1단지	㈜태영건설	787	2014-07-18	108-802	78.8	13.1	510.8	191.1	496.5	124.6
					110-301	128.2	13.7	545.0	200.3	528.3	137.1
					101-1005	83.6	15.4	609.8	221.0	575.2	148.3
					102-1201	114.7	16.7	630.3	222.0	575.6	144.3
					111-304	99.6	19.6	687.4	222.9	551.7	138.5
					113-1205	99.5	14.3	553.9	169.7	547.7	138.8
					103-201	120.4	13.0	486.3	182.6	470.5	118.8
					104-804	77.8	13.9	529.6	196.6	446.0	126.5
					105-201	137.2	15.3	591.6	219.5	565.0	142.3
					114-905	105.8	20.0	729.8	264.2	662.9	164.0
강남구	강남 A7BL	계룡건설산업㈜ 외 2	716	2014-09-29	704-104	30.0	2.0	163.0	47.0	74.0	29.0
					705-701	32.0	2.0	219.0	77.0	70.0	56.0
					707-1505	21.0	2.0	269.0	104.0	98.0	85.0
					708-104	17.0	2.0	236.0	108.0	109.0	45.0
					709-704	27.0	2.0	281.0	123.0	102.0	119.0
					710-1506	53.0	2.0	249.0	122.0	103.0	132.0
					701-106	21.0	3.0	259.0	84.0	133.0	46.0
					702-602	44.0	3.0	284.0	115.0	153.0	40.0
					703-1504	26.0	3.0	355.0	302.0	259.0	165.0
강남구	강남 A4BL	현대아산㈜ 외 1	402	2014-11-10	402-101	6.0	4.0	127.0	34.0	107.0	27.0
					406-703	7.0	4.0	146.0	28.0	58.0	38.0
					407-1504	7.0	4.0	128.0	54.0	97.0	35.0
					408-103	7.0	5.0	132.0	36.0	76.0	42.0
					409-804	7.0	4.0	112.0	30.0	54.0	37.0
					410-1501	7.0	4.0	158.0	42.0	70.0	56.0
송파구	군자녀기숙사	(주)대보실업 컨소시엄	300	2014-08-18	여사생실-403	79.4	1.7	205.5	16.5	22.1	30.5
					여사생실-1303	64.3	2.7	155.7	7.9	11.7	20.8
					여사생실-2405	65.1	2.9	228.8	32.9	17.2	59.2
					남사생실-402	59.2	2.0	130.7	37.8	97.9	27.4
					여사생실-1404	59.7	2.2	177.9	9.6	11.1	22.4
강동구	길동와이시티	요진건설산업	288	2014-01-10	1709	104.6	4.1	191.7	51.8	199.3	7.5
					1107	99.2	2.4	168.3	27.1	90.5	5.0
					1004	139.5	1.2	94.4	16.9	58.4	3.7
					509	40.2	2.6	128.3	53.1	194.9	3.0
					405	129.5	2.4	191.5	29.2	96.0	5.1
강남구	ACROHILSS	대림산업	368	2014-09-22	101-605	135.2	26.1	562.4	152.5	61.8	206.8
					101-1704	93.7	27.8	319.9	143.5	47.8	274.6
					102-1103	100.3	24.0	86.9	101.8	58.0	185.0
					102-1302	141.2	12.9	498.7	103.9	53.2	213.8
					103-2802	112.5	19.8	398.2	136.8	44.9	129.6
					104-402	105.1	18.9	142.9	148.5	41.9	154.3
은평구	은평뉴타운 3지구 12단지	(주) 한라	426	2014-12-05	1101-1003	193.4	N,D	938.4	111.0	262.7	24.6
					1103-1002	61.9	N,D	504.1	79.4	147.9	16.8
					1104-702	74.0	0.3	943.6	171.9	172.5	30.7
					1105-702	86.7	N,D	868.0	139.4	141.8	24.7
					1107-207	106.3	N,D	968.2	70.1	106.9	69.6
					1108-207	78.6	N,D	773.4	146.1	198.8	36.6
중구	청계천 두산위브 더제니스	두산중공업㈜	295	2014-11-13	A-3102	9.3	0.0	150.9	12.6	29.5	25.1
					A-2110	7.8	0.0	169.5	14.2	28.2	31.9
					B-2106	25.1	0.0	244.9	31.0	62.5	12.7
					B-705	15.7	0.0	171.2	10.1	24.0	12.0